



www.cowboycampsite.com

Skagit County Fire Marshal & CCMA Campfire Design and Use Standards

- Recreational fires are limited to 3 feet in diameter & 3 feet high*
- Fires must consist only of seasoned firewood, charcoal or propane fuel
- Fire-pit enclosures must be at least 14 inches high and no wider than 36 inches, constructed of cement blocks, stones or #10-gauge steel
- Fire-pit must have 18 inch radius of rock or gravel around the ring
- Burning materials must be kept below the top of the enclosure
- Two 5-gallon buckets or containers of water must be available on site
- Someone 16 years old or older must be present to monitor the fire
- Do not have fires when the wind is strong or allow flying embers
- Fires must be 10 feet from combustibles, timber or overhanging trees*

***The following additional restrictions apply when the
Skagit County Fire Marshal declares a Modified Burn Ban:**

- Recreational fires are limited to 3 feet diameter & 2 feet high
- Fires must be 25 feet from combustibles, timber or overhanging trees
- Properly contained propane fires are allowed

Skagit County Fire Marshall may impose a complete burn ban at any time

Examples of fire pit designs:

